



CERTIFICATE OF COMPLIANCE

SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS



Certification No.

VMA-53266-02C (Revision 2)

Expiration Date: 12/31/2026

Certification Parameters:

The nonstructural products (mechanical and/or electrical components) listed on this certificate are CERTIFIED¹ FOR SEISMIC APPLICATIONS in accordance with the following building code² releases.

IBC 2018, 2015, 2012, 2009; EC8 2004

The following model designations, options, and accessories are included in this certification. Reference report number VMA-53266-02 as issued by The VMC Group for a complete list of certified models, included accessories/options, and certified installation methods.

**Teksan; Diesel Gensets
TJ Series**

The above referenced equipment is APPROVED for seismic application when properly installed³, used as intended, and contains a Seismic Certification Label referencing this Certificate of Compliance⁴. As limited by the tabulated values, below grade, grade, and roof-level installations, installations in essential facilities, for life safety applications, and/or of equipment containing hazardous contents are permitted and included in this certification with an Equipment Importance Factor assigned as $I_p=1.5$. The equipment is qualified by successful seismic shake table testing at the nationally recognized Eucentre Pavia Italy under the witness of the ISO Accredited Product Certification Agency, the VMC Group.

Certified Seismic Design Levels			
Certified IBC	Importance $I_p \leq 1.5$ Soil Classes A-E Risk Categories I-IV Design Categories A-F	$z/h \leq 1.0$	$z/h = 0.0$
Certified EC8 ⁸	Importance $Y_a \leq 1.5$ Soil Classes A-E, Type I-II	$a_g \leq 0.124 \text{ g}$	$a_g \leq 0.281 \text{ g}$

Certified Seismic Installation Methods	
Rigid Mounting From Unit Base To Rigid Structure	External Isolation Mounting From Unit Base To Rigid Structure

HEADQUARTERS
113 Main Street
Bloomingdale, NJ 07403
Phone: 973.838.1780
Toll Free: 800.569.8423
Fax: 973.492.8430

CALIFORNIA
180 Promenade Circle
Suite 300
Sacramento, CA 95834
Phone: 916.634.7771

TEXAS
11930 Brittmoore Park Drive
Houston, TX 77041
Phone: 713.466.0003
Fax: 713.466.1355

thevmcgroup.com





CERTIFICATE OF COMPLIANCE

SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Certified Product Table:

Model	Max. Rating [kVA]	Max. Length [in.]	Max. Width [in.]	Max. Height [in.]	Max. Weight [lbs]	To	Model	Max. Rating [kVA]	Max. Length [in.]	Max. Width [in.]	Max. Height [in.]	Max. Weight [lbs]
TJ550PE-DCR	550	138	72	86	9995	To	TJ910PE-DCR	910	181	81	90	14688
TJ600PE5L-SA	600				9906		TJ1100PE5L-SA	1000				15825
TJ600PE5L-SB					9992		TJ1130PE5L-SB	1130				15800
TJ1000PE-DCR	1000	181	81	90	15800		TJ2250PE-DCR	2500	236	90	113	31682
TJ1250PE5L-SB	1252	185		87	20360		TJ2500PE5L-SB					32925

Ranges of certified Genset product are shown. For full list of certified models, directly contact the manufacturer.

Type	S _{DS} (z/h=0)	S _{DS} (z/h=1)	A _{Flex-H}	A _{Rig-H}	A _{Flex-V}	A _{Rig-V}	F _p /W _p
AC156	1.50	1.50	2.4	1.8	1.01	0.41	1.08

This certification includes the TJ Series Diesel Gensets and included factory supplied options. This certification only covers listed Gensets models. The Genset and applicable options shall be installed per the manufacturer supplied seismic installation instructions. For a list of certified configurations and options please directly contact the manufacturer. This certification excludes all non-factory supplied accessories and options, including but not limited to isolation (not outlined in certification report)/restraint devices, other electrical/mechanical components and all connections for electrical, fuel, heating or cooling fluid, or other pipe/conduit connections and configurations not detailed in the above charts. Flexibility in the connections must be maintained as to not transmit load into the equipment. Design specials are outside the scope of this certification.



VMA-53266-02C (Revision 2)
Issue Date: Friday, December 11, 2020
Revision Date: Thursday, March 28, 2024
Expiration Date: Thursday, December 31, 2026



CERTIFICATE OF COMPLIANCE

SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Cross-Code Compliance:

EC8 Approved Equivalent a_g							
Earthquake Type	Install Height	f_1/f_a					
		0.01	0.10	0.50	1.0	2.0	100.0
Type 2 Only	z/h = 0.0	0.525	0.461	0.281	0.213	0.533	0.533
Type 1 Only		0.374	0.374	0.361	0.274	0.374	0.374
Type 1 and Type 2		0.281	0.213	0.374	0.374		
Type 2 Only	z/h = 1.0	0.211	0.189	0.124	0.097	0.213	0.533
Type 1 Only		0.271	0.244	0.159	0.125	0.274	0.374
Type 1 and Type 2		0.211	0.189	0.124	0.097	0.213	

- * The type of earthquake to use per country/region is listed in the national annex
- * The f_1/f_a is fundamental frequency of the building divided by that of the component
- * The column for f_1/f_a can be used as the most conservative approved ground motion



VMA-53266-02C (Revision 2)
Issue Date: Friday, December 11, 2020
Revision Date: Thursday, March 28, 2024
Expiration Date: Thursday, December 31, 2026



CERTIFICATE OF COMPLIANCE

SEISMIC DESIGN OF NONSTRUCTURAL COMPONENTS AND SYSTEMS

Notes & Comments:

1. All equipment listed herein successfully passed the seismic acceptance criteria for shake testing non-structural components and systems as set forth in the ICC AC-156. The Test Response Spectrum (TRS) enveloped the Required Response Spectrum (RRS) for all units tested. The tested units were representative sample(s) of a contingent of models and all remained captive and structurally sound after the seismic shake simulation. The units also remained functionally operational after the simulation testing as functional testing was completed by the equipment manufacturer before and after the seismic simulations. Although a seismic qualified unit inherently contains some wind resisting capacity, that capacity is undetermined and is excluded from this certification. Snow/Ice loads have been neglected and thus limit the unit to be installed both indoors (covered by an independent protective structure) and out of doors (exposed to accumulating snow/ice) for ground snow loads no greater than 30 psf for all applications.
2. The following building codes are addressed under this certification:
 - IBC 2018 referencing ASCE7-16 and ICC-ES AC-156
 - IBC 2015 referencing ASCE7-10 and ICC-ES AC-156
 - IBC 2012 referencing ASCE7-10 and ICC-ES AC-156
 - IBC 2009 referencing ASCE7-05 and ICC-ES AC-156
 - EC8 2004 full reference Eurocode EN-1998 2004
3. Refer to the manufacturer supplied installation drawings for anchor requirements and mounting considerations for seismic applications. Required anchor locations, size, style, and load capacities (tension and shear) may be specified on the installation drawings or specified by a 3rd party. Mounting requirement details such as anchor brand, type, embedment depth, edge spacing, anchor-to-anchor spacing, concrete strength, special inspection, wall design, and attachment to non-building structures must be outlined and approved by the Engineer of Record for the project or building. Structural walls, structural floors, and housekeeping pads must also be seismically designed and approved by the project or building Structural Engineer of Record to withstand the seismic anchor loads as defined on the installation drawings. The installing contractor is responsible for ensuring the proper installation of all anchors and mounting hardware.
4. For this certificate and certification to remain valid, this certificate must correspond to the "Seismic Certification Label" found affixed to the unit by the factory. The label ensures the manufacturer built the unit in conformance to the IBC seismic design criteria set forth by the Certified Seismic Qualification Agency, the VMC Group, and meets the seismic design levels claimed by this certificate.
5. Mechanical, Electrical, and Plumbing connections to the equipment must be flexibly attached as to not transfer load through the connection. The structural integrity of any conduit, cable trays, piping, ductwork and/or flexible connections is the responsibility of others. This certification makes no statements of compliance in regards to NEMA, IP, UL, CSA, or other relevant standards after a seismic event. For compliance to other relevant standards, please contact the manufacturer.
6. This certificate applies to units manufactured at:
Yenidogan Mah. Edebali Cd. No: 12 PK:34791 Sancaktepe / ISTANBUL / TURKEY
7. This certification follows the VMC Group's ISO-17065 Scheme.
8. The Eurocode 8 maximum ground motion for equipment installed at grade or roof listed assumes that the fundamental frequency of the component is exactly twice that of the building (approximately 5 times more stiff compared to the building). If the frequency of the building or equipment is not known for a particular project, the cross-code table for EC8 may be used after the certified product table for the value of f_1/f_a as it represents the worst case amplification (and thus approves the lowest most conservative maximum ground motion).

John P. Giuliano, PE
President, VMC Group



VMA-53266-02C (Revision 2)
Issue Date: Friday, December 11, 2020
Revision Date: Thursday, March 28, 2024
Expiration Date: Thursday, December 31, 2026

